

# Fails Report

## Portable Appliance Safety Testing

Test Status: Fail, Test Type: All  
Person: All, Instrument: All  
From: 01/07/2013 To: 31/07/2013

<b>Client:</b> Selectatest Ltd	<b>Site:</b> JSelect	<b>Location:</b> Office	
Asset ID: DLZ451	Description: FAN	User: DPARKER	Test Instrument: Y49-0220
Comments: EARTH FAIL		RECOMMENDATIONS - REPLACE/REPAIR	

Test Type	Date	Result	Unit	Status
Visual	16/07/2013			Pass
Insulation Resistance	16/07/2013	> 199	MOhm	Pass
Earth	16/07/2013	10	Ohms	Fail

Overall: Fail

Asset ID: DLZ492	Description: LEAD	User: DPARKER	Test Instrument: Y49-0220
Comments: VISUAL FAIL - DAMAGED FLEX		RECOMMENDATIONS - REPAIR/REPLACE	

Test Type	Date	Result	Unit	Status
Visual	16/07/2013			Fail

Overall: Fail

Total Tests: 2

*The Fails Report is similar to the Detailed Report, but filtered to include only items which failed the testing. Comments detailing the reason for failure and recommendations on what to do with the failed item are also listed. Should none of your tested items fail the testing, you will not receive a fails report.*